

**NOVATO SANITARY DISTRICT
SELF-MONITORING PROGRAM**

For: February 2018

COLLECTION SYSTEM OVERFLOWS FOR FEBRUARY 2018

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in February 2018.

The No Spill Certification Confirmation number is: 2510577

For: JANUARY 2018

COLLECTION SYSTEM OVERFLOWS FOR JANUARY 2018

The Novato Sanitary District Collection System had no (zero) sanitary system overflows (SSOs) in January 2018.

The No Spill Certification Confirmation number is: 2508261

For: December 2017

COLLECTION SYSTEM OVERFLOWS FOR DECEMBER 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in December 2017.

The No Spill Certification Confirmation number is: 2504912

For: November 2017

COLLECTION SYSTEM OVERFLOWS FOR NOVEMBER 2017

The Novato Sanitary District Collection System had one sanitary sewer overflow (SSO) in November 2017.

1. Thursday, November 16, 2017, Alameda Del Prado, Novato, CA, 4,200 gallon SSO, CIWQS Event ID 841604, Certification ID 667941, Category 1 event.

EVALUATION OF OVERFLOWS FOR NOVEMBER 2017

275 Alameda Del Prado: This event was reported into the CIWQS database on November 16, 2017 as a Category 1 event with an estimated spill volume of 4,200 gallons, SSO Event ID # 841604 and was certified in CIWQS on November 27, 2017, Certification ID # 667941.

Initial actions

1. On Thursday, November 16, 2017, at 9:05AM, NSD employee Julie Hoover received a call from Veronica at the City of Novato reporting that a manhole was overflowing on Alameda del Prado. Aaron Hendricks and PJ Siragusa were dispatched immediately. Julie contacted Dasse de Longh and informed him of the reported overflow. Dasse contacted Javier Vega and all responded to the site.
2. Aaron, PJ, Joe Moreno and Brennan Duke arrived on site at 9:15AM and observed manhole K26014 at 725 Alameda del Prado overflowing. The crew began work to clear the stoppage. Dasse and Javier arrived moments later. Dasse took photos to document the event while the crew relocated across the freeway to break the stoppage. The overflow was entering a nearby catch basin so Joe and Aaron created a berm in the gutter pan for containment. The storm drain was actively flowing due to overnight rain.
3. PJ and Brennan set up the hydro-flusher at manhole K25090 on the opposite side of the freeway. The stoppage was broken at 9:41AM. Grease and rags were observed and collected after the stoppage was broken.
4. Cleanup and Recovery: After shooting the line several times, the hydro-flusher crew returned to the overflow site to recover the contained material and complete cleanup activities. Staff was able to recover 50 gallons of the discharge from the gutter that was previously bermed up.
5. Volume Estimation: The initial estimate is 4,200 gallons escaped from two manholes. The estimate was based on volumetric calculations, photos taken at the scene and crew observations using the CWEA SSCSC Manhole Overflow Gauge.

Reporting:

1. Dasse reported the Category 1 SSO to Cal-EMA at 11:01AM, within the required two-hour reporting window.
2. At 11:11AM, he contacted David Smail of Marin County Environmental Health Services to report the overflow. It was determined that, due to the circuitous route of the storm drain system, the fenced, marsh like conditions of the receiving waters and the heavy overnight rainfall, posting and sampling would not be necessary.
3. This event was reported into the CIWQS database on November 16, 2017 as a Category I event with an estimated spill volume of 4,200 gallons, SSO Event ID # 841604 and was certified in CIWQS on November 27, 2017, Certification ID # 66794.

Follow-up actions

1. Follow up CCTV inspection revealed grease accumulation in the sewer main. This line segment was last cleaned using a hydro-flusher truck on November 23, 2016 and is on a 12-month frequency.

2. The cleaning frequency will be increased to every 6 months.
3. Staff distributed grease and wipes informational flyer packets to residents upstream of the overflow.

For: October 2017

COLLECTION SYSTEM OVERFLOWS FOR OCTOBER 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in October 2017.

The No Spill Certification Confirmation number is: 2500247

For: September 2017

COLLECTION SYSTEM OVERFLOWS FOR SEPTEMBER 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in September 2017.

The No Spill Certification Confirmation number is: 2497829

For: August 2017

COLLECTION SYSTEM OVERFLOWS FOR AUGUST 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in August 2017.

The No Spill Certification Confirmation number is 2495916

For: JULY 2017

COLLECTION SYSTEM OVERFLOWS FOR JULY 2017

The Novato Sanitary District Collection System had two overflows in July, 2017:

2. Friday, July 7, 2017, 676 Plum Street, Novato, CA, 776 gallon SSO, CIWQS Event ID 837648, Certification ID 188184, Category 3 event of which 78% was recovered.
3. Wednesday, July 26, 2017, Marin Country Club, Hole 11, Novato, CA, 4,050 gallon SSO, CIWQS Event ID 837552, Certification ID 178244, Category 1 event of which 0.0% was recovered.

EVALUATION OF OVERFLOWS FOR JULY 2017

1. 676 Plum Street: This SSO was categorized as a Category 3 event because the overflow volume did not exceed one-thousand gallons and did not reach receiving waters of the state. The discharge volume was estimated to be 776 gallons. Staff recovered an estimated 600 gallons (78%) of the spill. This discharge was determined to be the result of grease accumulation in the sewer main.

Initial actions

1. On Friday, July 7, 2017, at 2:20PM, Julie Hoover received a call from the homeowner at 676 Plum Street reporting that a plumber she had contacted to clear her lateral told her that the sewer main in the street appeared to be plugged because a manhole in the street was surcharged. Julie contacted Javier Vega and informed him of the surcharged manhole. Javier contacted PJ Siragusa & Liam O'Sullivan who responded to the site immediately.
2. PJ & Liam arrived on site at 2:24PM and began work to clear the stoppage. PJ verified the surcharged manhole condition and then surveyed the area and found sewage in the planter and on the walkway on the east side of the house at 676 Plum Street. PJ noted that the cleanout in the planter was not overflowing at the time indicating that the stoppage may be a partial stoppage. Meanwhile, Liam worked to clear the stoppage and broke the stoppage at 2:35 PM.
3. Steve Krautheim arrived on site at approximately 2:38 PM and inspected the area around the overflow and noticed that the overflow was entering a 4" yard drain. After interviewing the property owner it was discovered that the yard drain discharged into the storm drain in Plum Street.
4. The crew followed the route of the storm drain down Plum Street to Chase Street, then north to Cherry Street, and then west towards Armstrong Avenue. Staff found a dry catch basin full of dry gravel in front of 724 Cherry Street. The crew returned to the next catch basin upstream at 712 Cherry Street and began to vacuum up water from the catch basin while flushing the storm drain downstream to draw any water in the storm drain back to the catch basin and remove it.
5. Meanwhile, Aaron Hendricks retrieved the second hydroflusher from the treatment plant and returned to 676 Plum Street to commence cleanup operations with Javier. The crew cleaned up the yard and then flushed the yard drain and storm drain system with approximately 750 gallons of dye tainted chlorinated water. The crew followed up with the hydroflusher, flushing the accumulated water in the storm drain down to the catch basin at 712 Cherry Street where it was retrieved by the other truck.

6. Recovery: Staff was able to recover 600 gallons of the discharge from the storm drain system.
7. Volume Estimation: Volumetric calculations as well as staff and reporting party interviews were used to estimate the volume of this event.
8. This event was determined to be a Category 3 event because the discharge did not exceed 1,000 gallons and did not reach receiving waters of the state.

Follow-up actions

1. Follow up CCTV inspection revealed grease accumulation in the sewer main. This line segment was last cleaned using a hydro-flusher truck on April 17, 2015 and is on a 36-month frequency.

Subsequent Analysis and Actions

1. The cleaning frequency has been increased to every 12 months.
2. Staff distributed grease and wipes informational flyer packets to residents upstream of the overflow.
3. This event was reported into the CIWQS database on July 31, 2017 as a Category III event with an estimated spill volume of 776 gallons, SSO Event ID # 837648 and was certified in CIWQS on August 2, 2017, Certification ID # 188184.
2. **Marin Country Club, Hole 11**: This event was categorized as a Category 1 event because the final spill destination was a manmade pond on Arroyo San Jose Creek. The discharge volume was estimated to be 4,050 gallons. Staff was unable to recover any of the spill before it entered the pond or soaked into the ground. This discharge is suspected to be the result of the vandalism after the crew found a sand trap rake blocking the flow through the manhole.

Initial actions

1. On Wednesday, July 26, 2017, at 8:40am, Laura Creamer received a call from Kevin Pryseski of the Marin Country Club reporting that a manhole was overflowing and going into a pond at the golf course. Laura contacted Steve Krautheim, Field Services Manager and informed him of the report. Steve called Aaron Hendricks, CSW II who responded with Liam O'Sullivan CSW I to the reported location. Steve also contacted Dasse de longh, Collection Systems Superintendent and all responded to the site immediately.
2. Aaron & Liam arrived on site at 9:06am and were met by an employee of the golf course. Aaron went with the employee to locate the manhole while Liam set up the hydro-flusher. Dasse arrived on site and the crew began work to clear the stoppage. Steve arrived and assisted Dasse with taking

- photos to document the event. The manhole discharge was flowing overland approximately 15 ft. into Arroyo San Jose Creek that is dammed to create a pond for the golf course.
3. The stoppage was broken at 9:13am. Marin County Environmental Health Services and Cal-OES were both contacted to report the spill. The cause of the overflow was determined to be a sand trap rake from the golf course that was blocking the channel in the manhole allowing rags and debris to accumulate behind it and obstruct the flow.
 4. Recovery: Staff was unable to recover any of the spill before it entered the pond or soaked into the ground.
 5. Volume Estimation: The SSCSC Manhole Overflow Gauge as well as staff and reporting party interviews were used to estimate the volume of this event.
 6. This event was determined to be a Category 1 event because the discharge exceeded 1,000 gallons and the final spill destination was the Arroyo San Jose Creek.

Follow-up actions

1. The crew cleaned the manhole and removed five large yard waste bags of contaminated soil and debris.
2. Fourteen WARNING signs were posted around the pond.

Subsequent Analysis and Actions

1. Water quality sampling was conducted through Tuesday, August 1 as required by Marin County Environmental Health Services.
2. Follow up CCTV work was performed to confirm that there were no other contributing factors to the overflow. None were found.
3. This event was reported into the CIWQS database on July 27, 2017 as a Category 1 event with an estimated spill volume of 4,050 gallons, SSO Event ID # 837552 and was certified in CIWQS on August 2, 2017, Certification ID # 178244

For: June 2017

COLLECTION SYSTEM OVERFLOWS FOR JUNE 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in June 2017.

The No Spill Certification Confirmation number is: 2489768

For: May 2017

COLLECTION SYSTEM OVERFLOWS FOR MAY 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in May 2017.

The No Spill Certification Confirmation number is: 2487664

For: April 2017

COLLECTION SYSTEM OVERFLOWS FOR APRIL 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in April 2017.

The No Spill Certification Confirmation number is: 2484632

For: March 2017

COLLECTION SYSTEM OVERFLOWS FOR MARCH 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in March 2017.

The No Spill Certification Confirmation number is: 2482077

For: February 2017

COLLECTION SYSTEM OVERFLOWS FOR FEBRUARY 2017

The Novato Sanitary District Collection System had no (zero) sewer system overflows (SSOs) in February 2017.

The No Spill Certification Confirmation number is: 2480636
